

## 4 Classification and field of application

## 4.1 Reference of classification

This classification has been carried out in accordance with BS EN 13501-1: 2018.

A1

The additional classification in relation to smoke production is:

The additional classification in relation to flaming droplets / particles is:

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation products is:

Fire Behaviour	Smoke Production		Flaming Droplets			
A1	-	s			d	-

i.e., A1

## Reaction to fire classification: A1

## 4.3 Field of application

This classification is valid for:

i) Cavity tray.

And the following product and mounting and fixing parameters:

Parameter	Field of application		
Colour	As tested. No variation in colour allowed.		
Finish/facing	As tested. No variation in finish allowed.		
Coating	Series one and amprovation of the second of		
Composition, including type and quantity of additives and flame retardants	As tested. No variation in composition allowed.		
Build-up and ordering of layers	As tested. No variation in build-up or ordering of layers allowed.		
Overall thickness	As tested. No variation in overall thickness allowed.		